



EMERGENCY GENERATORS
Requirements for Permitting and Installation
(OPTIONAL STANDBY FOR RESIDENTIAL USE)

Emergency generators must be submitted as a package with the following Two (2) copies of Site Plan (survey) highlighting the location of the generator:

1. Electrical Permit Application.
2. Two (2) copies of the Electrical Riser Diagram showing entire service, including:
 - a. Transfer switch.
 - b. All conduit and wire sizes.
 - c. Overcurrent protection of generator and equipment.
3. Two (2) copies of the Generator Specifications (usually supplied by the manufacturer). Specifications must provide length, width and height of the generator to be used.
4. Two (2) copies of Site Plan (survey) highlighting the location of the generator:
 - a. Showing exact location of proposed generator (minimum 5' from building openings). Exhaust must be minimum 10' from building openings.
 - b. Showing exact location of fuel tank (if applicable).
 - c. Providing the dimensions of the distances between the proposed generator/fuel tank and the side and rear property lines (setbacks).
 - d. Providing verification that generator will be installed at current base flood elevation or above per FBC 3110.1.2 and FBC R301.2.4 FEMA.

Note: Mechanical equipment and generators cannot be closer than 5' to the property lines and 10' to the water. Equipment can be no larger than 40 sq. ft. in area and 5' in height.

5. A Building Permit Application is required if a slab is to be poured:
 - a. If the slab is existing or "prefab", a building permit is not required.
 - b. The slab must be a minimum of 4" thick and comply with standards set forth by FBC 1820.5.
 - c. Specifications for generator anchorage for wind loads per FBC 1612.1.2.

Note: It is the responsibility of the contractor to verify that the soil bearing capacity will support the slab and generator.

6. If natural or LP gas is used, a Plumbing Permit Application is required from a licensed contractor.
7. Two(2) Isometric Rise Diagrams with plan view:
 - a. Showing total length and type of piping and chart used to size gas system.
 - b. Showing generator BTU rating.
8. If a non-self-contained diesel fuel generator is proposed, a Mechanical Permit Application is required. In addition, the plan showing diesel fuel holding tanks must be approved by EDP.

Note: Portable generators will be reviewed on a case-by-case basis.